

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:59 pm

**PWS ID:** UTAH26023      **Name:** STORM HAVEN RESIDENTS  
**Legal Contact:** STORM HAVEN      **Rating:** Approved  
 SUZANNE GOODFELLOW      **Rating Date:** 10/14/1985  
**Address:** 4782 COVE LN      **Activity Status:** Active  
 HEBER CITY, UT 84032  
**Phone Number:** 435-654-3119  
**City Served (Area):**  
**County:** WASATCH COUNTY  
**System Type:** Community      **Last Inv Update:** 11/30/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 04/29/2008      **Total Dsgn Cap:**  
**Population:** 100      **Surveyor:** DWIGHT HILL      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers	Email Address
			Office	Emergency
AC	GOODFELLOW, SUZANNE		435-654-3119	

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	52
			52 Total Svc Connections

### Storage

**Total Storage:** 24,000 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	20 K TANK	Ground	20,000 GAL	Steel		A	NO
ST002	4 K TANK	Ground	4,000	Concrete		A	NO

### Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	BOOSTER PUMP	A		P			

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	STORM HAVEN WELL 1	Active	WL	8	55 GPM	96 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.